



## AQUARIUS WASTEWATER SYSTEMS PTY LTD

ABN 43 609 521 735

**Manufacturer of the AQUARIUS® Range of Products**  
**Distributor for Graf® Range of Products**

Telephone 61+ (0)8 9240 8545  
Facsimile 61+ (0)8 9240 8542  
Email [admin@aquariuswastewater.com.au](mailto:admin@aquariuswastewater.com.au)  
Website [www.aquariuswastewater.com.au](http://www.aquariuswastewater.com.au)

Unit 1 / 20 Abrams Street  
Balcatta WA 6021  
Postal Address P O Box 623  
Balcatta WA 6914

Thank you for purchasing your Aquarius Wastewater Systems product. We know you will enjoy the benefits of using our system and we are pleased you chose to use our quality range of products to assist with your wastewater management. We trust that you are happy with your installation and we are confident that your system is running smoothly upon start-up. To assist with start-up, warranty activation and continual maintenance please refer to the following:

### **Warranty Activation**

To activate your warranty, it is very important that you please return a copy of your completed "Warranty Registration Form" provided with your owner user manual as soon as possible to Aquarius Wastewater Systems Pty Ltd.

### **Department of Health Western Australia Registration**

In order to meet the department of health Western Australia ATU requirements the following must be completed and returned to Aquarius Wastewater Systems PTY Ltd as soon as possible.

- ☐ Permit to Use – Completed and signed off by local shire
- ☐ Signed Service and Maintenance Agreement
- ☐ Warranty Registration Form - Completed

**Direct all queries and return the above forms to:**

**Email:** [support@aquariuswastewater.com.au](mailto:support@aquariuswastewater.com.au)

**Office:** Unit 1/20 Abrams Street, Balcatta

**Postal Address:** P O Box 623 Balcatta WA 6914

In the event of a problem arising, please contact your service agent / installing agent to rectify the problem.

It is important to understand that the ATU system is responsible for processing raw sewage and waste. It is possible there may be smells and odours present in the first 6-8 weeks which is the time it takes for the bioactive enzymes in the system to become properly activated. If odours emanating from the plastic lid cover during this period are undesirable, as a temporary measure it is recommended to cover the lid with a plastic sheet, then cover this plastic sheet with sand and check that the sewer ventilation is correctly installed.

Ensure that all P-traps under sinks and within floor grates are filled with water to aid with odour minimalization. In the event of misuse of the system please make use of the Bioactive Enzymes additive such as Zoxzyme, which will help process the waste and reduce smells or odours emitting from the unit.

Please refer to your product owner user manual instructions for further troubleshooting maintenance and warranty information.